

COMBUSTION

| Line P1 | |
|-----------------------|----------------------------|
| Commissioned | 2001 |
| Output | 45 MW |
| Combustion capacity | 16 tonnes/h, 10,8 MJ/ |
| | tonne |
| Grate supplier | Martin |
| Steam boiler | 40 bars 400°C |
| Steam production | 60 tonnes/h |
| Line P4 and P5 | |
| Commissioned | 1994-95 |
| Output | 2 x 54 MW |
| Combustion capacity | 2 x 22 tonnes/h, |
| | 10,5 MJ/tonne |
| Grate supplier | von Roll |
| Steam boiler | 40 bars 400°C |
| Steam production | 2 x 73 tonnes/h |
| Line P7 | |
| Commissioned | 2009 |
| Output | 39,1 MW |
| Combustion capacity | 14 tonnes/h, 11,2 MJ/tonne |
| Grate supplier | Martin |
| Steam boiler | 40 bars 400°C |
| Steam production | 52,7 tonnnes/h |
| Waste bunker | |
| No. of tipping sites | 14 |
| Actual useable volume | 22,000 m ³ |
| No. of waste cranes | 2 |
| Lift capacity | 14 tonnes each |
| Grab volume | 10 m³ each |
| | |

| Slag bunker | |
|----------------------|----------------------|
| Actual usable volume | 1,500 m ³ |
| Slag crane | 1 |
| Lift capacity | 8 tonnes |
| Grab volume | 3,2 m ³ |

STEAM AND ELECTRICITY

Steam turbine

| Otodini tarbino | ADD VAXIVIT IT +1,0 IVIV |
|---------------------------------------|--------------------------|
| Generator | ABB 47,7 kVA |
| Turbine condenser | |
| When turbine operation | |
| Condenser output at full load | 115 MW |
| During by-pass (heat production only) | |
| Maximum condenseroutput | 170 MW |
| Back-up condenser | |
| Heat output | 170 MW |

HEATING AND ELECTRICITY TO APARTMENTS AND RESIDENCES

Our energy production not only serves residential households but also businesses and industries. For added clarity, we have standardized our capacity measurement using residences as the benchmark.

In 2024, the Sävenäs waste-to-energy plant delivered 1 376 000 MWh of heat, equivalent to the annual heat and hot water demand for 135 000 apartments, each with an area of 70 $\rm m^2."$

The production of the Sävenäs waste-to-energy plant also delivered 221 404 MWh of electricity, which corresponds to the annual demand for 110 500 apartments of the same size.



ABB Vax MT 17 41.6 MW

FLUE GAS CLEANING

| Electrostatic precipitator lines | |
|---|------------|
| Collection efficiency, particles | > 99,5 % |
| Max particle content after electrostatic precipitator | 25 mg/N m³ |
| (in normal state, dry gas and 11 % O2) | |

| Wet flue of | gas cleaning | with cond | lensing P4 | and P5 |
|-------------|--------------|-----------|------------|--------|
| | | | | |

Two-stage scrubber, acid and alkaline stages with Adiox fillers and condenser reactor with direct condensation and cooling with absorption heat pumps.

Wet flue gas cleaning with condensing P1 and P7

Hot water economizer, spray scrubber for HCl and heavy metals, alkaline scrubber for SO_2 with direct condensation stage, wet electrostatic precipator (venturi type), condensing scrubber connected to absorption heat pumps.

| DeNO _x -facility P4 and P5 | |
|---------------------------------------|----------------------------|
| SNCR (non-catalytic reduction) | and flue gas recirculation |
| Reduction agent | 25 % ammonia |

| DeNO _x -facility P1 and P7 | |
|---------------------------------------|----------------------|
| SCR (catalytic reduction) and fl | ue gas recirculation |
| Catalyzer in 3 layers | |
| Reduction agent | 25 % ammonia |

| Bag house filter P4 and P5 | |
|-----------------------------|----------------------------|
| Flue gas flow lines 4 and 5 | 115 000 Nm ³ /h |

| Chimney | | |
|---------------------------|-------|--|
| Height above ground level | 126 m | |

FLUE GAS EMISSIONS

| Substance mg/m³ | Annual average 2022 | Environmental permit (average over 24 hrs) | EU-Directive (average over 24 hrs) |
|---------------------|---------------------------|--|--|
| Particles | 0,9 | - | 10 |
| TOC | 0,4 | - | 10 |
| NH_3 | 0,5 | 10 | - |
| HCI | 0,2 | - | 10 |
| CO | 22 | - | 50 |
| NO_X | 44*/24** | 80*/50** | - |
| SO ₂ | 1,4 | - | 50 |
| HF*** | 0,002 | - | 1 |
| N ₂ O*** | 4,5 | 10 | 10 |
| Hg*** | 4,8 | 30 | 50 |
| Dioxins*** | 0,01 | - | 0,1 (ng/m³) |

All values are expressed as normal m³ dry gas at 11 % O_2 mg/ m³. *Lines P1, P4 and P5 **Line P7 *** Measurment twice a year

| Flue gas speed | Approx 15 m/s |
|------------------------|---------------------------------------|
| No. of gas flues | 4 |
| Diameter of gas flue | 1,6 m |
| Material P1, P4 and P5 | Corten steel |
| Material P7 | Fibreglass-reinforced polyvinyl ester |

| Absorption heat pumps | |
|-------------------------------|--|
| Flue gas condensation | |
| Refrigerating capacit | 4 x 4 MW (Thermax) 2 x 6 MW (Weir-Entropie) |
| Process cooling | |
| Cooling output | 1 x 1,5 MW (Thermax) |
| Cooling of cleaned condensate | |
| Heat output | 1 x 1,5 MW (Carrier) Total 80 MW |

| Cooling tower | |
|------------------------|----------------------|
| Refrigerating capacity | 3 x 20 MW |
| Cooling medium | External air + water |



